



LAST WIRE No 22

DOOR WIDTH	AIRBLOC MODEL	No OF MODULES		TOTAL No OF FANS
		AB175	AB225	
5.25M	AB525	3	-	9
5.75M	AB575	2	1	10
6.25M	AB625	1	2	11
6.75M	AB675	-	3	12

SINGLE MOTOR FLC 5.2A

MOTOR LEAD COLOURS
 RED LOW SPEED
 BLUE MEDIUM SPEED
 BLACK HIGH SPEED
 WHITE NEUTRAL

REV	DATE	DESCRIPTION
2	23/03/18	MCB AND CONTACTOR CHANGED
1	22/12/15	MAINS ISOLATOR SWITCHED NEUTRAL

Wiring Colour Scheme
 Phases.....: **Black**
 Control 230V.....: **Red**
 Neutral.....: **Light Blue**
 24 VAC.....: **Violet**
 24 VAC Ground.: **White**
 24 VDC.....: **Dark Blue**
 0-10 VDC.....: **Orange**
 Analogue Inputs: **Grey**

TITLE **SCHEMATIC WIRING DIAGRAM FOR AMBIENT TRIPLE MODULE AIR CURTAIN 415v 3PH+N SUPPLY**

CLIENT **STANDARD**

DRAWN **SH**

DATE **12/09/12**

CHECKED **JC**

APPROVED

NORTEK
 GLOBAL HVAC

JOB No **STANDARD**

DRAWING No **CP-AB-TRIPLE-AMBIENT R2**

REVISION **2**

SHEET **1 of 1**

Essex Road Avenue
 Marlow, UK
 UK Tel: 01294 449 715
 Fax: 01294 449 707